

**DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS
Sample Location: 1970 Highway 20, **Eastern End**
Date Collected: 03/13/2019

Operator: Hagensborg Water District Trustees
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQT6 Lab: BCCDC
Sample ID: MSGE-B8F24Q Lab Sample ID: B9WW013329

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:

Total Coliform per 100 mL: 1
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700