



Hagensborg Waterworks & Fire Protection District <hwwdistrict@gmail.com>

Drinking Water Report for Hagensborg Waterworks District WS - 3/10/2016

1 message

HS Agent <HAgent@healthspace.com>
Reply-To: Phil Muirhead <phil.muirhead@vch.ca>
To: hwwdistrict@gmail.com

Tue, Mar 15, 2016 at 11:56 AM

**DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS
Sample Location: Highway 20, Rattcliff Residence
Date Collected: 03/10/2016

Operator: Chris Matthews
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-8CZVL4 Lab: BCCDC
Sample ID: MSGE-A6MPXD Lab Sample ID: B6WW013818

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:

Total Coliform per 100 mL: Less than 1
E. Coli per 100 mL: Less than 1

Comments:

L:LESS THAN LAUNDRY ROOM TAP COPIED FROM SAMPLE BOTTLE LABEL.]

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700