

**DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS
Sample Location: 1970 Highway 20, **Eastern End**
Date Collected: 03/27/2019

Operator: Hagensborg Water District Trustees
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQT6 Lab: BCCDC
Sample ID: MSGE-B8F24R Lab Sample ID: B9WW015986

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:

Total Coliform per 100 mL: 5
E. Coli per 100 mL: Less than 1

Comments:
L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

**DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS
Sample Location: 960 North Grant Road, **Western End**
Date Collected: 03/28/2019

Operator: Hagensborg Water District Trustees
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQMV Lab: BCCDC
Sample ID: MSGE-B8F24L Lab Sample ID: B9WW015987

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:

Total Coliform per 100 mL: 5

E. Coli per 100 mL: Less than 1

Comments:

L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

**DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS

Sample Location: Highway 20, **Fire Hall**

Date Collected: 03/28/2019

Operator: Hagensborg Water District Trustees

P.O. Box 25

Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQWS Lab: BCCDC

Sample ID: MSGE-B8F24X Lab Sample ID: B9WW015985

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:

Total Coliform per 100 mL: 2

E. Coli per 100 mL: Less than 1

Comments:

L:LESS THAN

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700