

**DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS
Sample Location: 960 North Grant Road, **Western End**
Date Collected: 09/04/2019

Operator: Hagensborg Water District Trustees
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQMV Lab: BCCDC
Sample ID: MSGE-BD8R6J Lab Sample ID: B9WW050609

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:

Total Coliform per 100 mL: EST 8
E. Coli per 100 mL: EST 1

Comments:

EST:ESTIMATED COUNT EST RESULT INDICATES HIGH COLONY DENSITY ON
MEMBRANE PREVENTING ACCURATE COLIFORM COUNTING. NO DATE
COLLECTED GIVEN SEP 4 COPIED FROM SAMPLE BOTTLE LABEL]

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

**DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS
Sample Location: Highway 20, **Fire Hall**
Date Collected: 09/04/2019

Operator: Hagensborg Water District Trustees
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQWS Lab: BCCDC
Sample ID: MSGE-BD8R6Q Lab Sample ID: B9WW050610

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:

Total Coliform per 100 mL: EST 30

E. Coli per 100 mL: EST 1

Comments:

EST:ESTIMATED COUNT EST RESULT INDICATES HIGH COLONY DENSITY ON
MEMBRANE PREVENTING ACCURATE COLIFORM COUNTING. NO DATE
COLLECTED GIVEN [SEP 4 COPIED FROM SAMPLE BOTTLE LABEL]

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700