

**DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS  
Sample Location: 1970 Highway 20, **Eastern End**  
Date Collected: 09/09/2020

Operator: Hagensborg Water District Trustees  
P.O. Box 25  
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQT6 Lab: BCCDC  
Sample ID: MSGE-BPTNGY Lab Sample ID: H1301027

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

**WATER TEST RESULTS:**

Total Coliform per 100 mL: 20  
E. Coli per 100 mL: 2

Comments:

Date of collection copied from sample bottle label.

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

**DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS  
Sample Location: Highway 20, **Fire Hall**  
Date Collected: 09/09/2020

Operator: Hagensborg Water District Trustees  
P.O. Box 25  
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQWS Lab: BCCDC  
Sample ID: MSGE-BPTNH2 Lab Sample ID: H1301026

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

**WATER TEST RESULTS:**

Total Coliform per 100 mL: ESTCT 290 ESTHCD

E. Coli per 100 mL: LT1

Comments:

Date of collection copied from sample bottle label.

ESTCT: Estimated Count

ESTHCD: High colony density on membrane prevented accurate coliform count.

LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

**DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS

Sample Location: 960 North Grant Road, **Western End**

Date Collected: 09/09/2020

Operator: Hagensborg Water District Trustees

P.O. Box 25

Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQMV Lab: BCCDC

Sample ID: MSGE-BPTNGR Lab Sample ID: H1301028

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

**WATER TEST RESULTS:**

Total Coliform per 100 mL: 1

E. Coli per 100 mL: LT1

Comments:

Date of collection copied from sample bottle label.

LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700