

**DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS  
Sample Location: 960 North Grant Road, **Western End**  
Date Collected: 09/05/2018

Operator: Hagensborg Water District Trustees  
P.O. Box 25  
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQMV Lab: BCCDC  
Sample ID: MSGE-B3UNDW Lab Sample ID: B8WW050454

**BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY**

**WATER TEST RESULTS:**

Total Coliform per 100 mL: 4  
E. Coli per 100 mL: Less than 1

Comments:  
L:LESS THAN

---

**FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700**

**DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS  
Sample Location: Highway 20, **Fire Hall**  
Date Collected: 09/05/2018

Operator: Hagensborg Water District Trustees  
P.O. Box 25  
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQWS Lab: BCCDC  
Sample ID: MSGE-B3UNEB Lab Sample ID: B8WW050452

**BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY**

**WATER TEST RESULTS:**

Total Coliform per 100 mL: EST 63

E. Coli per 100 mL: Less than 1

Comments:

EST:ESTIMATED COUNT L:LESS THAN EST RESULT INDICATES HIGH COLONY DENSITY ON MEMBRANE PREVENTING ACCURATE COLIFORM COUNTING.

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

**DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS

Sample Location: 1970 Highway 20, **Eastern End**

Date Collected: 09/05/2018

Operator: Hagensborg Water District Trustees

P.O. Box 25

Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQT6 Lab: BCCDC

Sample ID: MSGE-B3UNE6 Lab Sample ID: B8WW050453

**BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY**

**WATER TEST RESULTS:**

Total Coliform per 100 mL: 2

E. Coli per 100 mL: 1

---

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

