

BY-LAW NO. 69

A by-law for controlling the standards of domestic and commercial plumbing systems connected to the District's works.

The Trustees of Hagensborg Waterworks

District ENACT AS FOLLOWS:

1. Where any property owner within the District proposes to use water from the District's system he shall make formal application in writing to the District.
2. Subject to any provision of the "Subdivision Water Regulations By-law", the Trustees may approve the application for connection and the Trustees may specify the size, type, position and any other feature of the proposed service pipe installation.
3. The District shall be responsible for installing the service pipe from the point of connection with the District's pipeline to the outlet side of the controlling stop at the property line.
4. The property owner shall be responsible for the installation of the service pipe from the outlet of the stop up to and including the household or other system supplied.
5. All service pipes, including those inside buildings, subject to the direct water pressure from the District's system, shall be of copper or plastic pipe to approved waterworks standards and of a recommended operating pressure rating of not less than 160 pounds per square inch, except where otherwise authorized in writing by the District.
6. All buried service pipes shall have a minimum earth cover of five feet, measured from the top of the pipe to the normal ground surface adjacent to the pipe trench; except that in special cases minor deviation from this standard may be permitted by the Trustees in writing.
7. All buried service pipes shall be located in such a manner as to provide ease of access for repair.
8. The District may refuse a water connection to any property the internal plumbing for which does not meet the current specifications laid down in the National Building Code of Canada, or which does not conform to any other conditions which may be required by the Trustees.
9. All plumbing installations shall be inspected by the District whose written final approval is necessary before connection to the District's system is made.
10. The property owner shall install a controlling valve of a type approved

- 13. Every person who disobeys or fails to comply with any provision of this by-law shall be guilty of an offence and liable on summary conviction to a fine not exceeding Two Hundred Dollars (\$200.00) or to imprisonment not exceeding thirty days, or to both.
- 14. This by-law may be cited as "Installation Standards Control By-law".

INTRODUCED and given first reading by the Trustees
 on the *1st* day of *November*, 1980.
 RECONSIDERED and finally passed by the Trustees
 on the *1st* day of *November*, 1980.

Tony Carl Trotter
 Chairman of the Trustees

Edaine M. Guss
 Secretary of the Trustees

I hereby certify under the seal of Hagensborg Waterwork District that this is a true copy of By-law No. 69 of Hagensborg Waterworks District passed by the Trustees on the *1st* day of *November*, 1980.

Edaine M. Guss
 Secretary of the Trustees

