



Collected on: Nov 13 2019 00:00

Received on: Nov 14 2019 00:00

Reported on: Nov 15 2019 00:00

Ordered by: VANCOUVER COASTAL COMMUNITY HEALTH
Reported to: ENV LAB COPY, BCCDC LAB COPY, VANCOUVER COASTAL COMMUNITY HEALTH

Printed on: 2019-11-18 08:49
Page1 of 2

Sample: 04U0666
ENVBAC

ENVIRONMENTAL
BACTERIOLOGY
Phone Number :

Printed :2019 NOV 15

Requisition :B9WW065256
Submitter Ref :MSGE-BGTTUP

VANCOUVER COASTAL HEALTH AUTHORITY* - 251 Specimen Submitter
132 ESPLANADE W 5TH FLOOR
NORTH VANCOUVER BC V7M 1A2 :251-VANCOUVER COASTAL HEALTH A*

Site Information-----

Code/Name :04U0666 - HAGENSBORG WATERWORKS DISTRICT WS WESTERN END 960 NORTH GRANT ROAD

Site Desc :HAGENSBORG WATERWORKS DISTRICT WS WESTERN END 960 NORTH GRANT ROAD

City/Area : Type :COM.W.S.-2

Source :[SURFACE]

Specimen-----

Treatment:UNTREATED Ph Level: Free Chlorine Level: ppm

Nature :WATER Exams Req :Total Coliform

EHO :PHIL MUIRHEAD :Escherichia coli

Collected:2019 NOV 13

Received :2019 NOV 14

RESULTS=====

Reported on 2019 NOV 15

Test	Result	Units
1. Total Coliform (MF-Chromocult)	1	TC Count/100ml
2. Escherichia coli (MF-Chromocult)	L1	EC Count/100ml
L:LESS THAN		



Collected on: Nov 13 2019 00:00
Received on: Nov 14 2019 00:00
Reported on: Nov 15 2019 00:00

Printed on: 2019-11-18 08:49
Page 2 of 2

Ordered by:
Reported to:

VANCOUVER COASTAL COMMUNITY HEALTH
ENV LAB COPY, BCCDC LAB COPY, VANCOUVER COASTAL
COMMUNITY HEALTH

Specimen was 24 hours in transit
Coliform test may NOT be valid if specimen was more than 30 hrs in transit

Collected on: Nov 13 2019 00:00
Received on: Nov 14 2019 00:00
Reported on: Nov 15 2019 00:00



Ordered by: VANCOUVER COASTAL COMMUNITY HEALTH
Reported to: ENV LAB COPY, BCCDC LAB COPY, VANCOUVER COASTAL COMMUNITY HEALTH

Printed on: 2019-11-18 08:49
Page 1 of 2

Sample: 04U0665
ENVBAC

ENVIRONMENTAL
BACTERIOLOGY
Phone Number :

Printed :2019 NOV 15

Requisition :B9WW065255
Submitter Ref :MSGE-BGTTUT

VANCOUVER COASTAL HEALTH AUTHORITY* - 251 Specimen Submitter
132 ESPLANADE W 5TH FLOOR
NORTH VANCOUVER BC V7M 1A2 :251-VANCOUVER COASTAL HEALTH A*

Site Information-----

Code/Name :04U0665 - HAGENSBORG WATERWORKS DISTRICT WS EASTERN END 1970 HIGHWAY 20
Site Desc :HAGENSBORG WATERWORKS DISTRICT WS EASTERN END 1970 HIGHWAY 20
City/Area : Type :COM.W.S.-2
Source :[SURFACE]

Specimen-----

Treatment:UNTREATED Ph Level: Free Chlorine Level: ppm
Nature :WATER Exams Req :Total Coliform

EHO :PHIL MUIRHEAD :Escherichia coli

Collected:2019 NOV 13
Received :2019 NOV 14

RESULTS=====

Reported on 2019 NOV 15

Test	Result	Units
1. Total Coliform (MF-Chromocult)	6	TC Count/100ml
2. Escherichia coli (MF-Chromocult)	1	EC Count/100ml

Collected on: Nov 13 2019 00:00

Received on: Nov 14 2019 00:00

Reported on: Nov 15 2019 00:00



Ordered by: VANCOUVER COASTAL COMMUNITY HEALTH
Reported to: ENV LAB COPY, BCCDC LAB COPY, VANCOUVER COASTAL
COMMUNITY HEALTH

Printed on: 2019-11-18 08:49
Page2 of 2

Specimen was 24 hours in transit
Coliform test may NOT be valid if specimen was more than 30 hrs in transit

Collected on: Nov 13 2019 00:00
Received on: Nov 14 2019 00:00
Reported on: Nov 15 2019 00:00



Ordered by: VANCOUVER COASTAL COMMUNITY HEALTH
Reported to: ENV LAB COPY, BCCDC LAB COPY, VANCOUVER COASTAL COMMUNITY HEALTH

Sample: 04U0664
ENVBAC

ENVIRONMENTAL
BACTERIOLOGY
Phone Number :

Printed :2019 NOV 15

Requisition :B9WW065254
Submitter Ref :MSGE-BGTTUX

VANCOUVER COASTAL HEALTH AUTHORITY* - 251 Specimen Submitter
132 ESPLANADE W 5TH FLOOR
NORTH VANCOUVER BC V7M 1A2 :251-VANCOUVER COASTAL HEALTH A*

Site Information

Code/Name :04U0664 - HAGENSBORG WATERWORKS DISTRICT WS FIRE HALL HIGHWAY 20
Site Desc :HAGENSBORG WATERWORKS DISTRICT WS FIRE HALL HIGHWAY 20
City/Area : Type :COM.W.S.-2
Source :[SURFACE]

Specimen

Treatment:UNTREATED Ph Level: Free Chlorine Level: ppm
Nature :WATER Exams Req :Total Coliform

EHO :PHIL MUIRHEAD :Escherichia coli

Collected:2019 NOV 13
Received :2019 NOV 14

RESULTS

Reported on 2019 NOV 15

Test	Result	Units
1. Total Coliform (MF-Chromocult)	10	TC Count/100ml
2. Escherichia coli (MF-Chromocult)	L1	EC Count/100ml
L:LESS THAN		

Collected on: Nov 13 2019 00:00

Received on: Nov 14 2019 00:00

Reported on: Nov 15 2019 00:00



Ordered by: VANCOUVER COASTAL COMMUNITY HEALTH
Reported to: ENV LAB COPY, BCCDC LAB COPY, VANCOUVER COASTAL
COMMUNITY HEALTH

Printed on: 2019-11-18 08:49
Page2 of 2

Specimen was 24 hours in transit
Coliform test may NOT be valid if specimen was more than 30 hrs in transit