

**DRINKING WATER REPORT**  
**VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS  
Sample Location: 1970 Highway 20, **Eastern End**  
**Date Collected: 01/28/2020**

Operator: Hagensborg Water District Trustees  
P.O. Box 25  
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQT6 Lab: BCCDC  
Sample ID: MSGE-BL3VJS Lab Sample ID: M1155478

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

**WATER TEST RESULTS:**

Total Coliform per 100 mL: 4  
E. Coli per 100 mL: LT1

Comments:

Date of collection copied from sample bottle label.  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

**DRINKING WATER REPORT**  
**VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS  
Sample Location: Highway 20, **Fire Hall**  
**Date Collected: 01/28/2020**

Operator: Hagensborg Water District Trustees  
P.O. Box 25  
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQWS Lab: BCCDC  
Sample ID: MSGE-BGTTUY Lab Sample ID: T1130448

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

**WATER TEST RESULTS:**

Total Coliform per 100 mL: 4

E. Coli per 100 mL: LT1

Comments:

Date of collection copied from sample bottle label.

LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

**DRINKING WATER REPORT**  
**VANCOUVER COASTAL HEALTH**

Facility Name: Hagensborg Waterworks District WS

Sample Location: 960 North Grant Road, **Western End**

**Date Collected: 01/28/2020**

Operator: Hagensborg Water District Trustees

P.O. Box 25

Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQMV Lab: BCCDC

Sample ID: MSGE-BL3VJN Lab Sample ID: M1155496

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

**WATER TEST RESULTS:**

Total Coliform per 100 mL: LT1

E. Coli per 100 mL: LT1

Comments:

Date of collection copied from sample bottle label.

LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700