

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Hagensborg Waterworks District WS
Sample Location: 960 North Grant Road, **Western End**
Date Collected: 03/03/2020

Operator: Hagensborg Water District Trustees
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQMV Lab: BCCDC
Sample ID: MSGE-BL3VJP Lab Sample ID: M1155495

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: 2
E. Coli per 100 mL: LT1

Comments:
Date of collection copied from sample bottle label.
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Hagensborg Waterworks District WS
Sample Location: Highway 20, **Fire Hall**
Date Collected: 03/03/2020

Operator: Hagensborg Water District Trustees
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQWS Lab: BCCDC
Sample ID: MSGE-BL3VJW Lab Sample ID: M1155471

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: 1
E. Coli per 100 mL: LT1

Comments:
Date of collection copied from sample bottle label.
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Hagensborg Waterworks District WS
Sample Location: 1970 Highway 20, **Eastern End**
Date Collected: 03/03/2020

Operator: Hagensborg Water District Trustees
P.O. Box 25
Hagensborg, BC V0T 1H0

Site ID: PMUD-B2SQT6 Lab: BCCDC
Sample ID: MSGE-BL3VJT Lab Sample ID: M1155473

BOIL WATER NOTICE REMAINS IN PLACE ON THIS WATER SUPPLY

WATER TEST RESULTS:
Total Coliform per 100 mL: 2
E. Coli per 100 mL: LT1

Comments:
Date of collection copied from sample bottle label.
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Phil Muirhead (604) 983-6700